

**Inspection Checklist for Agent Specific- Newcastle Disease Virus (9 CFR 121; BMBL 6th Edition)****Entity Name:****Inspection Date:****Building/Rooms:****Inspectors:****When information is entered in this form, the form is to be considered "Sensitive Select Agent Information."**

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	All exhaust air derived from the containment area is HEPA-filtered.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Bio-isolators containing animals have HEPA-filtered exhaust air.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	The entity has implemented a personal quarantine or restriction policy. The policy prohibits laboratory staff and visitors from having contact with susceptible avian species for a minimum of 5 days after the last possible contact with the NDV virus. If there is no quarantine/restriction, then the entity is to provide a risk assessment to justify.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Employees and visitors read the personal quarantine/restriction policy, and acknowledge, by signature, their agreement to comply with that policy. Employees and visitors must sign annually.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	