

Inspection Checklist for Agent Special- Venezuelan Equine Encephalitis Virus; Rift Valley Fever Virus (9 CFR 121; BMBL 6th Edition)**Entity Name:****Inspection Date:****Building/Rooms:****Inspectors:****When information is entered in this form, the form is to be considered "Sensitive Select Agent Information."**

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	VEEV - HEPA filtration is required on the exhaust system of laboratory and animal facilities using VEE virus.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	RVFV- Personnel must use respiratory protection or be vaccinated for RVFV.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	RVFV- HEPA filtration on laboratory exhaust is required for RVF virus.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	