

Inspection Checklist for ABSL-2 Laboratories (7 CFR 331; 9 CFR 121; 42 CFR 73; BMBL 5th Edition)

Entity Name:
Inspection Date:
Street Address:
City, State, Zip:
RO:
ARO(s):

Lead Inspector:
Other Inspectors:

Building/Room(s):

PI(s):

HHS Agents:

Overlap Agents:

USDA Agents:

When information is entered in this form, the form is to be considered Sensitive Select Agent Information.

Entity Name:		Inspection Date:			
Reference	Statement	Yes	No	N/A	Comments
CFR: Section 12(a)	An individual or entity required to register under this part must develop and implement a written biosafety (biocontainment) plan that is commensurate with the risk of the select agent or toxin, given its intended use.				
CFR: Section 12(a)	The biosafety (biocontainment) plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent.				
CFR: Section 12(a)	The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.				
CFR: Section 12(a)(1)	The biosafety plan must include the hazardous characteristics of each agent or toxin listed on the entity's registration and the biosafety risk associated with laboratory procedures related to the select agent or toxin.				
CFR: Section 12(a)(2)	The biosafety plan must include safeguards in place with associated work practices to protect entity personnel, the public, and the environment from exposure to the select agent or toxin including, but not limited to: personal protective equipment and other safety equipment; containment equipment including, but not limited to, biological safety cabinets, animal caging systems, and centrifuge safety containers; and engineering controls and other facility safeguards.				

Entity Name:		Inspection Date:			
Reference	Statement	Yes	No	N/A	Comments
CFR: Section 12(a)(3)	The biosafety plan must include written procedures for each validated method used for disinfection, decontamination or destruction, as appropriate, of all contaminated or presumptively contaminated materials including, but not limited to: cultures and other materials related to the propagation of select agents or toxins, items related to the analysis of select agents and toxins, personal protective equipment, animal caging systems and bedding (if applicable), animal carcasses or extracted tissues and fluids (if applicable), laboratory surfaces and equipment, and effluent material.				
CFR: Section 12(a)(4)	The biosafety plan must include procedures for the handling of select agents and toxins in the same spaces with non-select agents and toxins to prevent unintentional contamination.				
CFR: Section 12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).				
CFR: Section 12(c)(1)	In developing a biosafety plan, an individual or entity should consider: The CDC/NIH publication, "Biosafety in Microbiological and Biomedical Laboratories". This document is available on the National Select Agent Registry website at http://www.selectagents.gov/ .				
CFR: Section 12(d)	The biosafety plan must include an occupational health program for individuals with access to Tier 1 select agents and toxins, and those individuals must be enrolled in the occupational health program.				
CFR: Section 12(e)	Drills or exercises must be conducted at least annually to test and evaluate the effectiveness of the plan.				
CFR: Section 12(e)	The plan must be reviewed and revised, as necessary, after any drill or exercise and after any incident.				
CFR: Section 12(e)	Drills or exercises must be documented to include how the drill or exercise tested and evaluated the plan, any problems that were identified and corrective action(s) taken, and the names of registered entity personnel participants.				

Entity Name:		Inspection Date:			
Reference	Statement	Yes	No	N/A	Comments
42 CFR 73: Section 13 (a)	An individual or entity may not conduct or possess products (i.e., select agents that are not known to acquire the resistance naturally, if such acquisition could compromise the control of disease agents in humans, veterinary medicine, or agriculture, or recombinant and/or synthetic nucleic acids containing genes for the biosynthesis of select toxins lethal for vertebrates at an LD[50] < 100 ng/kg body weight) resulting from, a restricted experiment with a HHS select agent or toxin unless approved by and conducted in accordance with any conditions prescribed by the HHS Secretary.				
42 CFR 73: Section 13 (a)	In addition, an individual or entity may not conduct or possess products (i.e., select agents that are not known to acquire the resistance naturally, if such acquisition could compromise the control of disease agents in humans, veterinary medicine, or agriculture, or recombinant and/or synthetic nucleic acids containing genes for the biosynthesis of select toxins lethal for vertebrates at an LD[50] < 100 ng/kg body weight) resulting from, a restricted experiment with an overlap select agent or toxin unless approved by and conducted in accordance with any conditions prescribed by the HHS Secretary, after consultation with Administrator.				
9 CFR 121: Section 13(a)	An individual or entity may not conduct or possess products (i.e., select agents that are not known to acquire the resistance naturally, if such acquisition could compromise the control of disease agents in humans, veterinary medicine, or agriculture, or recombinant and/or synthetic nucleic acids containing genes for the biosynthesis of select toxins lethal for vertebrates at an LD[50] < 100 ng/kg body weight) resulting from, the following experiments unless approved by and conducted in accordance with the conditions prescribed by the Administrator:				
A	Standard Microbiological Practices				
BMBL: A1	The animal facility director establishes and enforces policies, procedures, and protocols for institutional policies and emergency situations.				
BMBL: A1	Each organization must assure that worker safety and health concerns are addressed as part of the animal protocol review.				
BMBL: A1	Prior to beginning a study, animal protocols must also be reviewed and approved by the IACUC and the Institutional Biosafety Committee.				

Entity Name:		Inspection Date:			
Reference	Statement	Yes	No	N/A	Comments
BMBL: A2	A safety manual specific to the animal facility is prepared or adopted in consultation with the animal facility director and appropriate safety professionals.				
BMBL: A2	The safety manual must be available and accessible.				
BMBL: A2	Personnel are advised of potential hazards, and are required to read and follow instructions on practices and procedures. Consideration should be given to specific biohazards unique to the animal species and protocol in use.				
BMBL: A3	Supervisor must ensure that animal care, laboratory and support personnel receive appropriate training regarding their duties, animal husbandry procedure, potential hazards, manipulations of infectious agents, necessary precautions to prevent hazard or exposures, and hazard/exposure evaluation procedures (physical hazards, splashes, aerosolization, etc.).				
BMBL: A3	Personnel must receive annual updates or additional training when procedures or policies change.				
BMBL: A3	Records are maintained for all hazard evaluations, employee training sessions and staff attendance.				
BMBL: A4	Appropriate medical surveillance program is in place, as determined by risk assessment.				
BMBL: A4	The need for an animal allergy prevention program should be considered. Facility supervisors should ensure that medical staff is informed of potential occupational hazards within the animal facility, to include those associated with research, animal husbandry duties, animal care and manipulations.				
BMBL: A4	Personal health status may impact an individual's susceptibility to infection, ability to receive immunizations or prophylactic interventions. Therefore, all personnel and particularly women of child-bearing age should be provided information regarding immune competence and conditions that may predispose them to infection. Individuals having these conditions should be encouraged to self-identify to the institution's healthcare provider for appropriate counseling and guidance.				

Entity Name:		Inspection Date:			
Reference	Statement	Yes	No	N/A	Comments
BMBL: A4	Personnel using respirators must be enrolled in an appropriately constituted respiratory protection program.				
BMBL: A5	A sign incorporating the universal biohazard symbol must be posted at the entrance to areas where infectious materials and/or animals are housed or are manipulated when infectious agents are present.				
BMBL: A5	The sign must include the animal biosafety level, general occupational health requirements, personal protective equipment requirements, the supervisor's name (or other responsible personnel), telephone number, and required procedures for entering and exiting the animal areas.				
BMBL: A5	Identification of specific infectious agents is recommended when more than one agent is being used within an animal room. Security-sensitive agent information and occupational health requirements should be posted in accordance with the institutional policy.				
BMBL: A5	Advance consideration should be given to emergency and disaster recovery plans, as a contingency for man-made or natural disasters.				
BMBL: A6	Access to the animal room is limited. Only those persons required for program or support purposes are authorized to enter the animal facility and the areas where infectious materials and/or animals are housed or are manipulated.				
BMBL: A6	All persons including facility personnel, service workers, and visitors are advised of the potential hazards (natural or research pathogens, allergens, etc.) and are instructed on the appropriate safeguards.				
BMBL: A7	Protective laboratory coats, gowns, or uniforms are required to prevent contamination of personal clothing.				
BMBL: A7	Gloves are worn to prevent skin contact with contaminated, infectious and hazardous materials and when handling animals. Gloves and personal protective equipment should be removed in a manner that minimizes transfer of infectious materials outside of the areas where infectious materials and/or animals are housed or are manipulated.				
BMBL: A7	Persons must wash their hands after removing gloves, and before leaving the areas where infectious materials and/or animals are housed or are manipulated.				

Entity Name:		Inspection Date:			
Reference	Statement	Yes	No	N/A	Comments
BMBL: A7	Eye and face and respiratory protection should be used in rooms containing infected animals, as dictated by the risk assessment.				
BMBL: A8	Eating, drinking, smoking, handling contact lenses, applying cosmetics, and storing food for human consumption must not be permitted in laboratory areas. Food must be stored outside of the laboratory in cabinets or refrigerators designated and used for this purpose.				
BMBL: A9	All procedures are carefully performed to minimize the creation of aerosols or splatters of infectious materials and waste.				
BMBL: A10	Mouth pipetting is prohibited. Mechanical pipetting devices must be used.				
BMBL: A11	Policies for the safe handling of sharps, such as needles, scalpels, pipettes, and broken glassware must be developed and implemented.				
BMBL: A11	When applicable, laboratory supervisors should adopt improved engineering and work practice controls that reduce the risk of sharps injuries. Precautions, including those listed below, must always be taken with sharp items. These include:				
BMBL: A11-a	Needles and syringes or other sharp instruments are limited to use in the animal facility when there is no alternative for such procedures as parenteral injection, blood collection, or aspiration of fluids from laboratory animals and diaphragm bottles.				
BMBL: A11-b	Disposable needles must not be bent, sheared, broken, recapped, removed from disposable syringes, or otherwise manipulated by hand before disposal. Used disposable needles must be carefully placed in puncture-resistant containers used for sharps disposal.				
BMBL: A11-b	Sharps containers should be located as close to the work site as possible.				

Entity Name:		Inspection Date:			
Reference	Statement	Yes	No	N/A	Comments
BMBL: A11-c	Non-disposable sharps must be placed in a hard-walled container for transport to a processing area for decontamination, preferably by autoclaving.				
BMBL: A11-d	Broken glassware must not be handled directly; it should be removed using a brush and dustpan, tongs, or forceps.				
BMBL: A11-d	Plasticware should be substituted for glassware whenever possible.				
BMBL: A11-e	Equipment containing sharp edges and corners should be avoided.				
BMBL: A12	Equipment and work surfaces are routinely decontaminated with an appropriate disinfectant after work with an infectious agent, and after any spills, splashes, or other overt contamination.				
BMBL: A13	Animals and plants not associated with the work being performed must not be permitted in the areas where infectious materials and/or animals are housed or are manipulated.				
BMBL: A14	An effective integrated pest management program is required (See Appendix G in BMBL).				
BMBL: A15	All wastes from the animal room (including animal tissues, carcasses, and bedding) are transported from the animal room in leak-proof containers for appropriate disposal in compliance with applicable institutional, local and state requirements.				
BMBL: A15	Decontaminate all potentially infectious materials before disposal using an effective method.				
B	Special Practices				
BMBL: B1	Animal care staff, laboratory and routine support personnel must be provided a medical surveillance program as dictated by the risk assessment, and administered appropriate immunizations for agents handled or potentially present, before entry into animal rooms. When appropriate, a base line serum sample should be stored.				

Entity Name:		Inspection Date:			
Reference	Statement	Yes	No	N/A	Comments
BMBL: B2	Procedures involving a high potential for generating aerosols should be conducted within a biosafety cabinet or other physical containment device.				
BMBL: B2	When a procedure cannot be performed within a biosafety cabinet, a combination of personal protective equipment and other containment devices must be used.				
BMBL: B2	Restraint devices and practices that reduce the risk of exposure during animal manipulations (e.g., physical restraint devices, chemical restraint medications, etc.) should be used whenever possible.				
BMBL: B3	Decontamination by an appropriate method (e.g. autoclave, chemical disinfection, or other approved decontamination methods) is necessary for all potentially infectious materials and animal waste before movement outside areas where infectious materials and/or animals are housed or are manipulated. This includes potentially infectious animal tissues, carcasses, contaminated bedding, unused feed, sharps, and other refuse.				
BMBL: B3	A method for decontaminating routine husbandry equipment, sensitive electronic and medical equipment should be identified and implemented.				
BMBL: B3	Materials to be decontaminated outside of the immediate areas where infectious materials and/or animals are housed or are manipulated must be placed in a durable, leak proof, covered container and secured for transport.				
BMBL: B3	The outer surface of the container is disinfected prior to moving materials.				
BMBL: B3	The transport container must contain a universal biohazard label.				
BMBL: B3	Develop and implement an appropriate waste disposal program in compliance with applicable institutional, local and state requirements. Autoclaving of content prior to incineration is recommended.				
BMBL: B4	Equipment, cages, and racks should be handled in manner that minimizes contamination of other areas.				

Entity Name:		Inspection Date:			
Reference	Statement	Yes	No	N/A	Comments
BMBL: B4	Equipment must be decontaminated before repair, maintenance, or removal from the areas where infectious materials and/or animals are housed or are manipulated.				
BMBL: B4	Spills involving infectious materials must be contained, decontaminated, and cleaned up by staff properly trained and equipped to work with infectious material.				
BMBL: B5	Incidents that may result in exposure to infectious materials must be immediately evaluated and treated according to procedures described in the safety manual. All such incidents must be reported to the animal facility supervisor or personnel designated by the institution.				
BMBL: B5	Medical evaluation, surveillance, and treatment should be provided as appropriate and records maintained.				
C	Safety Equipment (Primary Barriers and Personal Protective Equipment)				
BMBL: C1	Properly maintained BSCs, personal protective equipment (e.g., gloves, lab coats, face shields, respirators, etc.) and/or other physical containment devices or equipment, are used whenever conducting procedures with a potential for creating aerosols or splashes. These include necropsy of infected animals, harvesting of tissues or fluids from infected animals or eggs, and intranasal inoculation of animals.				
BMBL: C1	When indicated by risk assessment, animals are housed in primary biosafety containment equipment appropriate for the animal species, such as solid wall and bottom cages covered with filter bonnets for rodents, or larger cages placed in inward flow ventilated enclosures or other equivalent primary containment systems for larger animal cages.				
BMBL: C2	A risk assessment should determine the appropriate type of personal protective equipment to be utilized.				
BMBL: C2	Scrub suits and uniforms are removed before leaving the animal facility. Reusable clothing is appropriately contained and decontaminated before being laundered.				
BMBL: C2	Laboratory and protective clothing should never be taken home.				

Entity Name:		Inspection Date:			
Reference	Statement	Yes	No	N/A	Comments
BMBL: C2	Gowns, uniforms, laboratory coats and personal protective equipment are worn while in the areas where infectious materials and/or animals are housed or manipulated and removed prior to exiting.				
BMBL: C2	Disposable personal protective equipment and other contaminated waste are appropriately contained and decontaminated prior to disposal.				
BMBL: C3	Eye and face protection (mask, goggles, face shield or other splatter guard) are used for manipulations or activities that may result in splashes or sprays from infectious or other hazardous materials and when the animal or microorganisms must be handled outside the BSC or containment device.				
BMBL: C3	Eye and face protection must be disposed of with other contaminated laboratory waste or decontaminated before reuse.				
BMBL: C3	Persons who wear contact lenses should also wear eye protection when entering areas with potentially high concentrations or airborne particulates.				
BMBL: C3	Persons having contact with the NHPs should assess risk of mucous membrane exposure and wear protective equipment (e.g., masks, goggles, face shields, etc.) appropriate for the task to be performed. Respiratory protection is worn based upon risk assessment.				
BMBL: C4	Gloves should be worn to protect hands from exposure to hazardous materials. A risk assessment should be performed to identify the appropriate glove for the task and alternatives to latex gloves should be available.				
BMBL: C4	Gloves are changed when contaminated, integrity has been compromised, or when otherwise necessary.				
BMBL: C4	Gloves must not be worn outside the animal rooms.				
BMBL: C4	Gloves and personal protective equipment should be removed in a manner that prohibits transfer of infectious materials.				
BMBL: C4	Do not wash or reuse disposable gloves.				

Entity Name:		Inspection Date:			
Reference	Statement	Yes	No	N/A	Comments
BMBL: C4	Dispose of used gloves with other contaminated waste.				
BMBL: C4	Persons must wash their hands after handling animals and before leaving the areas where infectious materials and/or animals are housed or are manipulated.				
BMBL: C4	Hand washing should occur after the removal of gloves.				
D	Laboratory Facilities (Secondary Barriers)				
BMBL: D1	The animal facility is separated from areas that are open to unrestricted personnel traffic within the building.				
BMBL: D1	External facility doors are self-closing and self-locking.				
BMBL: D1	Doors to areas where infectious materials and/or animals are housed or open inward, are self-closing, are kept closed when experimental animals are present, and should never be propped open.				
BMBL: D1	Doors to cubicles inside an animal room may open outward or slide horizontally or vertically.				
BMBL: D2	A hand washing sink is located at the exit of the areas where infectious materials and/or animals are housed or are manipulated.				
BMBL: D2	Additional sinks for hand washing should be located in other appropriate locations within the facility.				
BMBL: D2	If the animal facility has segregated areas where infectious materials and/or animals are housed or manipulated, a sink must also be available for hand washing at the exit from each segregated area.				
BMBL: D2	Sink traps are filled with water, and/or appropriate liquid to prevent the migration of vermin and gases.				

Entity Name:		Inspection Date:			
Reference	Statement	Yes	No	N/A	Comments
BMBL: D3	The animal facility is designed, constructed, and maintained to facilitate cleaning and housekeeping.				
BMBL: D3	The interior surfaces (walls, floors and ceilings) are water resistant.				
BMBL: D3	Penetrations in floors, walls and ceiling surfaces are sealed, to include openings around ducts, doors and door frames, to facilitate pest control and proper cleaning.				
BMBL: D3	Floors must be slip resistant, impervious to liquids, and resistant to chemicals.				
BMBL: D4	Cabinets and bench tops must be impervious to water and resistant to heat, organic solvents, acids, alkalis, and other chemicals.				
BMBL: D4	Spaces between benches, cabinets, and equipment should be accessible for cleaning.				
BMBL: D4	Furniture should be minimized.				
BMBL: D4	Chairs used in animal area must be covered with a non-porous material that can be easily cleaned and decontaminated.				
BMBL: D4	Furniture must be capable of supporting anticipated loads and uses.				
BMBL: D4	Sharp edges and corners should be avoided.				
BMBL: D5	External windows are not recommended; if present, windows should be sealed and must be resistant to breakage.				

Entity Name:		Inspection Date:			
Reference	Statement	Yes	No	N/A	Comments
BMBL: D5	The presence of windows may impact facility security and therefore should be assessed by security personnel.				
BMBL: D6	Ventilation should be provided in accordance with the Guide for Care and Use of Laboratory Animals.1				
BMBL: D6	The direction of airflow into the animal facility is inward; animal rooms should maintain inward directional airflow compared to adjoining hallways.				
BMBL: D6	A ducted exhaust air ventilation system is provided.				
BMBL: D6	Exhaust air is discharged to the outside without being recirculated to other rooms.				
BMBL: D6	Ventilation system design should consider the heat and high moisture load produced during the cleaning of animal rooms and the cage wash process.				
BMBL: D7	Internal facility appurtenances, such as light fixtures, air ducts, and utility pipes, are arranged to minimize horizontal surface areas, to facilitate cleaning and minimize the accumulation of debris or fomites.				
BMBL: D8	Floor drains must be maintained and filled with water, and/or appropriate disinfectant to prevent the migration of vermin and gases.				
BMBL: D9	Cages should be autoclaved or otherwise decontaminated prior to washing.				
BMBL: D9	Mechanical cage washer should have a final rinse temperature of at least 180°F.				
BMBL: D9	The cage wash area should be designed to accommodate the use of high pressure spray systems, humidity, strong chemical disinfectants and 180°F water temperatures, during the cage/ equipment cleaning process.				

Entity Name:		Inspection Date:			
Reference	Statement	Yes	No	N/A	Comments
BMBL: D10	Illumination is adequate for all activities, avoiding reflections and glare that could impede vision.				
BMBL: D11	If BSCs are present, they must be installed so that fluctuations of the room air supply and exhaust do not interfere with proper operations.				
BMBL: D11	BSCs should be located away from doors, heavily traveled laboratory areas, and other possible airflow disruptions.				
BMBL: D11	HEPA filtered exhaust air from a Class II BSC can be safely re-circulated back into the laboratory environment if the cabinet is tested and certified at least annually and operated according to manufacturer's recommendations. BSCs can also be connected to the laboratory exhaust system by either a thimble (canopy) connection or a directly to the outside through an independent, hard connection.				
BMBL: D11	Provisions to assure proper safety cabinet performance and air system operation must be verified.				
BMBL: D11	BSCs should be recertified at least once a year to ensure correct performance.				
BMBL: D11	All BSCs should be used according to manufacturer's specifications, to protect the worker and avoid creating a hazardous environment from volatile chemical and gases.				
BMBL: D12	If vacuum service (i.e., central or local) is provided, each service connection should be fitted with liquid disinfectant traps and an in-line HEPA filter, placed as near as practicable to each use point or service cock. Filters are installed to permit in-place decontamination and replacement.				
BMBL: D13	An autoclave should be considered in the animal facility to facilitate decontamination of infectious materials and waste.				
BMBL: D14	Emergency eyewash and shower are readily available; location is determined by risk assessment.				

Comments continued:

Inspector summary and comments:

Lead inspector:

Date:

Other inspectors present:

Date:

Lead inspector signature: _____

Date: _____